

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

HELENA JUBANY
PRESIDENT

VAN AMBATIELOS
VICE-PRESIDENT

E. FELICIA BRANNON
VICTOR H. CUEVAS
GEORGE HOVAGUIMIAN

CITY OF LOS ANGELES

CALIFORNIA



ERIC GARCETTI
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

RAYMOND S. CHAN, C.E., S.E.
SUPERINTENDENT OF BUILDING
INTERIM GENERAL MANAGER

Intermat
2045 Placentia Avenue
Costa Mesa, CA 92627

Attn: Carleton Elliott
(714) 412-8647

RESEARCH REPORT: RR 25461
(CSI #5160)

BASED UPON IAPMO EVALUATION
SERVICES REPORT NO. 0126

Expires: April 1, 2016
Issued: April 1, 2014
Code: 2014 LABC

GENERAL APPROVAL – Reevaluation - Sure-Board® Series 200 and 200W Structural Panels Installed on Cold-Formed Steel or Wood Framed Shear Walls

DETAILS

The above assemblies and/or products are approved when in compliance with the description, use, identification and findings of Evaluation Report No. 0126, issued January 2010, revised January 24, 2014, of the IAPMO Evaluation Services. The report, in its entirety, is attached and made part of this general approval subject to the following conditions.

The parts of Evaluation Report No. 0126 marked with an asterisk have been deleted or revised by the Los Angeles City Building Department from this approval.

The approval is subject to the following conditions:

1. Building design calculations and details shall be prepared by an engineer or architect licensed in the state of California and approved by the structural plan check engineer.
2. Special inspection for seismic resistance shall be conducted in accordance with the Sections 1707.3 and 1707.4 of the 2014 Los Angeles City Building Code.
3. All shear walls shall be provided with holdowns.

RR 25461
Page 1 of 3

